

Message

From: Hanchett, James (DPH) [/O=COMMONWEALTH OF MASSACHUSETTS/OU=MASSMAIL-01/CN=RECIPIENTS/CN=JAMES.HANCHETT]
Sent: 11/5/2012 2:51:58 PM
To: 'Ewart, Burt' [bewart@facil.umass.edu]
Subject: Vivarium Air

Hi Burt,

The air flow is messed up again in Vivarium, and it is affecting our lab in N236. The holes above ceiling should have been filled so it wouldn't happen.

Jim Hanchett
Department of State Police
Amherst Drug Lab
Room N251 Morrill I
637 North Pleasant Street
Amherst, MA 01003
Phone 413-545-2607
Fax 413-545-2608
Cell [REDACTED]